

PROCEEDING OF PRE BID QUERY HELD ON 26.12.2022 AT 3.30 PM RELATING TO SUPPLY, INSTALLATION AND COMMISSIONING OF CHLORINATION PLANT- 2 NOS AND R.O UNIT -1 NO TO THE NANDANKANAN IN THE CONFERENCE HALL OF OFFICE OF THE DEPUTY DIRECTOR, NANDANKANAN ZOOLOGICAL PARK.

Member Present

1. Deputy Director, Nandankanan Zoological Park
2. Assistant Conservator Of Forests- Cum-curator
3. Range Officer, Special Project Range
4. Range Officer, State Botanical Garden-I

The Pre bid Query meeting was held under the chairmanship of Deputy Director, Nandankanan Zoological Park in the Conference hall of Deputy Director, Nandankanan on 26.12.2022 at 3.30 PM to clarify the Queries by prospecting bidders relating to EOI No.50 dated 20.12.2022 for the project Supply, installation and commissioning of chlorination plant- 2 nos and R.O unit -1 no at Nandankanan.

The following bidders attended in the said meeting.


1. KOUSIK DE
zeolite (india)Pvt Ltd.
2. Sukanta Kumar Swain
3. Sanjeb Kumar Nayak
(S N pure water solution)

List of queries raised by prospecting bidders regarding “supply, installation and commissioning of chlorination plant- 2 nos and R.O unit -1 no at Nandankanan Zoological Park” in the Conference Hall of Office of Deputy Director, Nandankanan Zoological Park.


Sl No	Name	Query	Clarification
1	KOUSIK DE zeolite (India) Pvt. Ltd	Head pressure	Head pump could not be
		Storage in line between water tank	There is no intermediate storage between water bear chlorination unit to PM unit.
		Capacity of storage tank	The capacity of storage tank for SBG is 50000 liters instead of 2000 ltrs.
		Booster pump	Kirloskar make to be supplied.
	Consumption of water	Consumption of water to be supplied to all the enclosures and its requirement is for 20hrs a day.	
2	Sukanta Kumar Swain	Civil Work for installation of chlorination plant	The civil work will be done by the department.
		Supply of electricity to the chlorination plant	The electricity will be supplied to the chlorination plant by the department.


		CMC	Submission of paper item wise cost . The cmc cost should be include supply of the liquid, material for monthly maintenance & repairment of the unit.
3	Sanjeb Kumar Nayak (SN pure water solution)	Over head tank	Overhead tank to be constructed by the deptt. of 20000litres.
		Repair & maintenance	Repair & Maintenance work to be supplied by the bidder. The maintenance material and repair work to be supplied by the bidder.


After discussion and the clarification given by the Chairpersōn the meeting ended with vote of thanks to the chair.


Assistant Conservator of Forests,
Visitor Management


Range Officer,
Special Project Range


Assistant Conservator of Forests,
Cum-curator


Range Officer,
State Botanical Garden-I


Deputy Director
Nandankanan Zoological Park